POWER SUPPLY BOARD

POWER CONNECTION AND ELO

CONNECT TO HOUSE ELECTRICAL IN ACCORDANCE WITH AS3000. PROVIDE SEPARATE CIRCUIT FROM METER BOARD WITH CIRCUIT BREAKER

PANEL TO BE PAD LOCKED WITH STANDARD KEY LOCK

VENT

POWER CABLE

CONTROL PANEL

MINIMUM 1200mm ABOVE GL 400mm ABOVE FLOOD LEVEL AS DETERMINED BY AUTHORITY

MINIMUM 1800mm CLEARANCE

CABLE INSTALLATION IN ACCORDANCE WITH AS3000

OVERFLOW RELIEF GULLY

BOLTED TRAP SCREW SEWER BOX WITH CONCRETE SURROUND

MINIMUM 1000mm CLEAR SPACE AROUND PUMP UNIT

MAINS PROPERTY SERVICE

SEWER EASEMENT ALLOTMENT

BOUNDARY KIT REFER TO DETAIL PROPERTY ISOLATION VALVE

POPERTY BOUNDARY

PRESSURE STREET MAIN

ELECT CABLE

45°

45°

COVER IN ACCORDANCE WITH AS 3500. MIN 400mm COVER : 600mm COVER UNDER DRIVEWAYS

DETECTABLE WARNING TAPE

150mm

HOUSE PRESSURE MAIN

INDICATIVE ONLY HOUSE GRAVITY DRAINAGE SYSTEM IN ACCORDANCE WITH AS 3500

EXISTING HOUSE SERVICE

40mm PE OUTSIDE DIAMETER TYPICAL

1000mm APPROX

PVC SCREWED CAP TO TOP OF JUNCTION INSTALLED BY LIC PLUMBER TO REQUIRED DEPTH

MONO SEWER PUMP WELL

45 JUNCTIONS

VERTICAL 100mm PVC CONNECTION

P.S.SOLUTIONS

PRESSURE SEWER SOLUTIONS PTY LTD
P.O. Box 630
JANNALI NSW 2226
PH: +61 2 9584 1177
ABN: 57 097 164 899

Mono NOV
Cnr Marshall & Ethell Roads Kirrawee
New South Wales 2232, Australia
PH +61 2 8536 0900,
Fax: +61 2 9542 3649
www.mono-pumps.com

TYPICAL HOUSE CONNECTION DETAIL